

CITY AND BOROUGH OF WRANGELL, ALASKA
Wrangell Ozone Generator Procurement

ADDENDUM TO THE CONTRACT

Addendum No: Two (2)
Pages this Addendum One (1)
Previous Addenda Issued: One (1)

Previous Bid Opening Date: August 20, 2015 at 10:00 a.m.

Current Bid Opening Date: August 24, 2015 at 10:00 a.m.

To: All Bidders of Record

August 14, 2015

The contract documents are modified as indicated herein. All other terms and conditions remain unchanged. Bidders are required to acknowledge this addendum. Make the following additions to the contract documents:

1. DATE AND TIME FOR BID OPENING

Change the bid opening date to Monday, August 24, 2015 at 10:00 a.m. Prevailing Time.

2. ANSWERS TO BIDDER'S QUESTIONS

A. Please specify whether the following monitors are existing or are these to be provided by the Ozone System Supplier:

i. Q: Dew point monitor

A: The City & Borough of Wrangell has a dew point monitor.

ii. Q: High concentration ozone monitor

A: The City & Borough of Wrangell has a high concentration ozone monitor.

iii. Q: Ambient ozone monitor

A: The City & Borough of Wrangell has an ambient ozone monitor.

iv. Q: Dissolved ozone monitor

A: The City & Borough of Wrangell does not have a dissolved ozone monitor; however, we would like to ensure that we have the ability to incorporate this monitor into our system in the future. Bidders are not required to include such as device in their bid.

v. Q: Backflow prevention device

A: The City & Borough of Wrangell currently does not have the need for a backflow prevention device due to the design of our water plant system; however,

if a Bidder's equipment requires a device to monitor the output line for water intrusion, then such device should be included in their bid.

vi. Q: Air cooled chiller

A: The City & Borough of Wrangell currently does not have an air cooled chiller. Wrangell's water temperature averages 12 degrees Celsius, but we have a seasonal range from 1-16 degrees Celsius.

B. Q: Will both of Wrangell's existing PSA units operate to provide the oxygen to one ozone generator?

A: The City & Borough of Wrangell currently has two ozone generators, each of which requires 296 scfh to operate. Because we are only replacing one of the two existing ozone generators, we must reserve the capacity to serve the second unit. The intended operation is that one air train will serve each ozone generator, whether new or existing.

C. Q: If a Bidder's equipment does not require a chiller for the cooling water, can the generator be operated using the plant water as shown in the contract drawing C02?

A: The City & Borough of Wrangell currently use the plant's water without the need for a chiller, and it is our intent to acquire new generators which will operate in this same fashion.

END OF ADDENDUM NO. 2