

**CITY AND BOROUGH OF WRANGELL,
ALASKA INVITATION TO BID
SHOEMAKER HARBOR NET FLOAT REPLACEMENT**

ADDENDUM TO THE PROJECT DOCUMENTS

Addendum No: 1

Current Bid Date:

July 8, 2021 at 2:00 pm AK Standard Time

Addendum Date: July 8, 2021

Pages This Addendum: One (1)

Previous Addenda: None

To: All Proposers

The following corrections, changes, additions, deletions, revisions and/or clarifications are hereby made a part of the Documents for the Invitation to Bid for the Shoemaker Harbor Net Float Replacement project. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Item No. 1 SUMMARY OF WORK

Section B, 1., is replaced in its entirety as follows:

1. New galvanized steel shall meet the steel grade and standards in accordance with either of the following standards:
 - a. AWWA C200, Steel Water Pipe 6-Inch or Larger;
 - b. ASTM A-252, Grade 3 for spiral steel;
 - c. ASTM A-53, Grade B for seamless and welded mechanical and pressure applications; or
 - d. API-5L

Either steel option should meet a minimum yield strength of 240 Mpa, a minimum ultimate strength of 415 Mpa. Roundness of pipe should be such that splicing standards meet the tolerances provided by AWS.

END OF ADDENDUM NO. 1