

**CITY & BOROUGH OF WRANGELL, ALASKA
NON-MOTORIZED TRANSPORTATION SYSTEM**

ADDENDUM TO THE CONTRACT

Addendum No:	2	Current Bid Opening Date: August 29, 2023 at 2:00 P.M.
Pages This Addendum:	1	
Previous Addenda:	1	Previous Bid Opening Date: August 29, 2023 at 2:00 P.M.

To: All Planholders of Record

August 24, 2023

The contract documents are modified as indicated herein. All other terms and conditions remain unchanged. Bidders are required to acknowledge this addendum on the Bid Proposal. Make the following changes to the contract documents:

PROJECT MANUAL

DRAWINGS

1. Drawing Sheet STD_938-30-01, Step and Run, in the table, **Change** the size callout for the size of the plank from '2x14' to '2x10' and at all locations referenced on the sheet.
2. Drawing Sheet STD_911-03, Typical Retainers, **Add** the following note: Yellow cedar logs for retainers shall be debarked.
3. Drawing Sheet STD_911-40-01, Barrier Rail on Post, **Add** the following note: Yellow cedar logs for barrier rails shall be debarked.

END OF ADDENDUM NO. 2