

**CITY AND BOROUGH OF WRANGELL, ALASKA**

**INVITATION TO BID**

**Transformers Procurement – Alder Top  
Village Subdivision**

**ADDENDUM TO THE PROJECT DOCUMENTS**

---

**Addendum No:** 1

**Current Bid Date:**

July 16, 2024 at 2:00 pm  
AK Standard Time

**Addendum Date:** July 5, 2024

Pages This Addendum: One (1)

Previous Addenda: None

---

To: All Proposers.

The following corrections, changes, additions, deletions, revisions and/or clarifications are hereby made a part of the Documents for the Invitation to Bid for the Transformers Procurement – Alder Top Village Subdivision project. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This addendum \_\_\_\_\_ does, **X** **does not** change the bid opening date.

**Item 1: SECTION 160000 DISTRIBUTION TRANSFORMERS, A. RATINGS**

Replace A. Ratings as follows:

Type: Conventional (Externally accessible fuses; Boy-o-Net fuses are the basis of design); Deadfront;

Basis of Design: Cooper Systems Shrubline, ANSI Type II (Shrubline's optional feature of Vacuum Fault Interrupters (VFI) is not a requirement)

**END OF ADDENDUM NO. 1**