

**CITY AND BOROUGH OF WRANGELL, ALASKA**  
**INVITATION TO BID**  
**CITY DOCK SUMMER FLOAT PROCUREMENT**  
**ADDENDUM TO THE PROJECT DOCUMENTS**

---

<b>Addendum No:</b>	<b>1</b>	<b>Previous Bid Submittal Date:</b> January 21, 2020 at 2:00pm ADT
<b>Addendum Date:</b>	<b>Tuesday, January 21, 2020</b>	
Pages This Addendum:	TWO (2)	<b>New Bid Submittal Date:</b> January 24, 2020 at 2:00pm ADT
Previous Addenda:	None	

---

To: All Proposers

The following corrections, changes, additions, deletions, revisions and/or clarifications are hereby made a part of the Documents for the Invitation to Bid for the City Dock Summer Float Procurement project. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

**Item 1 SUMMARY OF WORK**

Section B. Galvanized Steel Fabrication Specifications, Subsection 1 is amended as follows:

1. New galvanized steel shall conform to ASTM A-252, Grade 3.

**Item 2. SUMMARY OF WORK**

Section B. Galvanized Steel Fabrication Specifications, Subsection 4 is amended as follows:

4. All splice joints shall have two baffle plates one quarter (1/4) inch thick, one each side of the joint.

**Item 3. PAGE 5, FIRST DRAWING**


Page 5, the first drawing is replaced with the attached drawing.

**Item 4. INSTRUCTIONS TO BIDDERS**

Section A is amended as follows:

Sealed bids will be received by the City and Borough of Wrangell, Post Office Box 531, Wrangell, Alaska 99929, or located at the Borough Clerk's Office, 205 Brueger Street, Wrangell, Alaska 99929, until 2:00 PM prevailing time on January 24, 2020, at which time the Bids will be publically opened and read aloud in the Assembly Chambers at City Hall, Wrangell, Alaska.


SIDE VIEW



BOAT HOLES MUST BE FINISHED DRILLING BE 1/2" GALVANIZING AFTER

TABS 1" X 12" 1/4" X 6"

120"



END VIEW