



City & Borough of Wrangell
P.O. Box 531, Wrangell, AK 99929
T 907.874.3494 / F 907.874.2699
Website www.wrangell.com
Email wrgpm@wrangell.com

ADDENDUM NO. 3

January 13, 2012

PROJECT: Etolin Street and Medical Campus Utilities Assistance

This Addendum forms a part of the Contract Documents and modifies the original Bidding Requirements dated December, 2011 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum does not change the bid opening date, which is currently set for January 17, 2012 at 2:00 PM.

TECHNICAL SPECIFICATIONS

DIVISION 2-SITE WORKS

1. Section 02405 – Lift Station Check Valve and Flow Meter. Replace this entire Section with the attached Section 02405, for both Check Valves and Flow Meter.

END OF ADDENDUM NO. 3

Etolin Street and Medical Campus
Utilities Assistance – Addendum #3

Section 02405 – Lift Station Check Valve and Flow Meter

1. CHECK VALVES

Shall be swing type spring and lever check valves and shall meet all applicable parts of ANSI/AWWA C508 Standard.

2. FLOW METER

- A) Shall be Badger magnetoflow magmeter flow tube with integral M-3000 Amplifier.
- B) Refer to telemetry requirements specified in Section 16900, 2.3F.

End Section 02405