

CITY & BOROUGH OF WRANGELL, ALASKA

**WRANGELL MARINE SERVICE CENTER
CONCRETE PAVING**

ADDENDUM TO THE CONTRACT

Addendum No:	1	Current Bid Opening Date: April 3, 2012 at 2:00 P.M.
Pages This Addendum:	Two (2)	
Previous Addenda:	None	Previous Bid Opening Date: April 3, 2012 at 2:00 P.M.

To: All Planholders of Record March 28, 2012

The contract documents are modified as indicated herein. All other terms and conditions remain unchanged. Bidders are required to acknowledge this addendum on the Bid Proposal. Make the following changes to the contract documents:

PROJECT MANUAL

Item No. 1 Section 02202 – Excavation and Embankment, Article 3.1, Paragraph H, number 1: Change the location of the “first pit” on Spur Road to the “second pit” on Spur Road.

Item No. 2 Section 02202 – Excavation and Embankment, Article 3.1, Paragraph H, item number 4, add following: The referenced Wrangell Municipal Code is Section 15.18.075 - Monofill disposal permit and fees

The CBW will waive the \$1.00/Cubic Yard disposal fee for this project.

DRAWINGS

Item No. 3 Drawing Sheets 2.02 through 2.06:

Replace the layout table point number's nothings, eastings and elevations as follows:

POINT	NORTHING	EASTING	ELEVATION
102	8765.36	10817.67	24.05
103	8762.68	10824.94	24.01
104	8770.01	10836.93	23.90
105	8754.17	10846.43	24.30
201	8838.29	10795.33	23.67
202	8908.19	10754.03	21.82
305	8833.08	10786.75	23.51

Item No. 4

Drawing Sheet 2.12, 17 of 18- Additive Alternate A Details:

Add Note 11 as follows:

11. Provide a 30"Ø opening with solid frame and grate HS 20 load rated over the outlet drop pipe and oil port. Provide a 24"Ø opening frame and inlet grate HS 20 load rated over the inlet drop tee per manufactures written recommendations or approved equal. (Incidental)

END OF ADDENDUM NO.1