

# **CITY OF WRANGELL 2019 WATER QUALITY REPORT AK2120143**

## **Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected one of those contaminants at a level higher than the EPA allows. As we informed you at the time, our water exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Our water comes from two surface reservoirs which are interconnected by a spillway when there is an abundance of water, and a drain located in the dam of the upper reservoir when the level drops below the spillway. They are located on Mount Wrangell south of town. After the raw water enters the plant, it is treated with ozone to remove iron, reduce the level of organics, and provide some initial disinfection. It is then filtered by two roughing filters, followed by four sand filters. Chlorine is added to disinfect the water as it is pumped to our two 424,000-gallon storage tanks for use.

## **Source water assessment and its availability**

Source Water Assessment (SWA) Reports have been completed by the ADEC Drinking Water Protection Program as a first step towards voluntary local source water protection efforts. Vulnerability rankings are assigned based on the susceptibility of the drinking water source to potential contamination, recent sampling results and the presence of potential contaminant sources - they do not necessarily indicate these contaminants will reach our source of water. Our water system has received the following vulnerability rankings: The public water system for City of Wrangell is a Class A water system consisting of 1 source intake. The water system is located in Wrangell and the intake for this water system, is a surface water source. The overall protection area received a susceptibility rating of "very high". In addition, this water system has received a vulnerability rating of "high" for bacteria/viruses, "very high" for nitrates/nitrites,

"high" for volatile organic chemicals, "high" for heavy metals, "medium" for other organic chemicals, and "medium" for synthetic organic chemicals.

Completed source water assessments are available at ADEC's Drinking Water Protection Program website: [http://www.dec.state.ak.us/eh/dw/DWP/source\\_water.html](http://www.dec.state.ak.us/eh/dw/DWP/source_water.html), by calling 907.269.7521, or at 555 Cordova St, Anchorage, AK; or at the Alaska Resources Library and Information Services, 3150 C St, Anchorage, AK. Contact the Environmental Protection Agency (EPA) at 1.800.426.4791. You may also find information on EPA's website at [www.epa.gov/safewater/protect.html](http://www.epa.gov/safewater/protect.html).

### **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

### **How can I get involved?**

If you have any questions about this report or concerning your water utility, please contact Wrangell City Hall at 907-874-2381. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled council meetings. They are held on the 2nd and 4th Tuesday of the month at City Hall.

### **Description of Water Treatment Process**

Your water is treated in a "treatment train" (a series of processes applied in a sequence) that includes coagulation, flocculation, sedimentation, filtration, and disinfection. Coagulation removes dirt and other particles suspended in the source water by adding chemicals (coagulants) to form tiny sticky particles called "floc," which attract the dirt particles. Flocculation (the formation of larger flocs from smaller flocs) is achieved using gentle, constant mixing. The heavy particles settle naturally out of the water in a sedimentation basin. The clear water then moves to the filtration process where the water passes through

sand, gravel, charcoal or other filters that remove even smaller particles. A small amount of chlorine or other disinfection method is used to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water before water is stored and distributed to homes and businesses in the community.

### **Water Conservation Tips**

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.
- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

### **Waivers:**

We have a SOC (Synthetic Organic Contaminants) monitoring waiver 2017-2019 as there have been none detected when sampled for. We will be re-applying for this waiver for the 2020-2022 sampling period.

### **Monitoring and reporting of compliance data violations**

The City did not send the CCR Certification Page to the State of Alaska DEC on time confirming the CCR was complete and available to consumers. Because of this oversight, we received a reporting violation. This violation will be returned to compliance when the certification requirements are met for the 2020 CCR.

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. WRANGELL is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and

components associated with service lines and home plumbing. WRANGELL is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

| Contaminants  | MCLG<br>or<br>MRDLG | MCL,<br>TT, or<br>MRDL | Detect<br>In<br>Your<br>Water | Range |      | Sample<br>Date | Violation | Typical Source   |
|---|---------------------|------------------------|-------------------------------|-------|------|----------------|-----------|--|
|   |                     |                        |                               | Low   | High |                |           |  |
| Disinfectants & Disinfection By-Products  |                     |                        |                               |       |      |                |           |  |
| (There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants) |                     |                        |                               |       |      |                |           |  |
| Bromate (ppb)   | 0                   | 10                     | 2.8                           | NA    | NA   | 2019           | No        | By-product of drinking water disinfection  |
| Haloacetic Acids (HAA5) (ppb)   | NA                  | 60                     | 39.95                         | 23.8  | 71   | 2019           | No        | By-product of drinking water chlorination  |
| TTHMs [Total Trihalomethanes] (ppb)   | NA                  | 80                     | 20.4                          | 14.5  | 31   | 2019           | No        | By-product of drinking water disinfection  |
| Inorganic Contaminants  |                     |                        |                               |       |      |                |           |  |
| Chromium (ppb)  | 100                 | 100                    | .68                           | NA    | NA   | 2011           | No        | Discharge from steel and pulp mills; Erosion of natural deposits                           |
| Barium (mg/L)   | 2                   | 2                      | 0.0047                        | Na    | NA   | 2011           | No        | Discharge of Drilling wastes, discharge from metal refineries, erosion of natural deposits |
| Nitrate [measured as Nitrogen] (ppm)  | 10                  | 10                     | .244                          | NA    | NA   | 2019           | No        | Runoff from fertilizer; Leaching from septic tanks, sewage; Erosion of natural deposits    |

| Contaminants                                 | MCLG<br>or<br>MRDLG | MCL,<br>TT, or<br>MRDL | Detect<br>In<br>Your<br>Water | Range          |                              | Sample<br>Date | Violation  | Typical Source              |
|--|---------------------|------------------------|-------------------------------|----------------|------------------------------|----------------|--|-----------------------------|
|  |                     |                        |                               | Low            | High                         |                |  |                             |
|  |                     |                        |                               |                |                              |                |  |                             |
| Radioactive Contaminants                     |                     |                        |                               |                |                              |                |  |                             |
| Alpha emitters (pCi/L)                       | 0                   | 15                     | .24                           | NA             | NA                           | 2017           | No   | Erosion of natural deposits |
| Radium (combined 226/228) (pCi/L)            | 0                   | 5                      | .66                           | NA             | NA                           | 2017           | No   | Erosion of natural deposits |
| Contaminants                                 | MCLG                | AL                     | Your<br>Water                 | Sample<br>Date | # Samples<br>Exceeding<br>AL | Exceeds<br>AL  | Typical Source   |                             |
| Inorganic Contaminants                       |                     |                        |                               |                |                              |                |  |                             |
| Copper - action level at consumer taps (ppm) | 1.3                 | 1.3                    | .71                           | 2017           | 0                            | No             | Corrosion of household plumbing systems; Erosion of natural deposits |                             |
| Inorganic Contaminants                       |                     |                        |                               |                |                              |                |  |                             |
| Lead - action level at consumer taps (ppb)   | 0                   | 15                     | 6.5                           | 2017           | 0                            | No             | Corrosion of household plumbing systems; Erosion of natural deposits |                             |

|   |
|---|
| <b>Violations and Exceedances</b>   |
| The CCR certification page verifying the 2019 CCR was made available to the public was not sent to the State in time This is a reporting violation. |

## Additional Contaminants

In an effort to ensure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed below were found in your water.

| Contaminants | State MCL | Your Water | Violation | Explanation and Comment      |
|--------------|-----------|------------|-----------|------------------------------|
| Nickel       | .1 MG/L   | 1.05 UG/L  | No        | Erosion of natural deposits. |

| <b>Unit Descriptions</b> |  |
|--------------------------|--|
| Term                     | Definition   |
| ppm                      | ppm: parts per million, or milligrams per liter (mg/L)   |
| ppb                      | ppb: parts per billion, or micrograms per liter (µg/L)   |
| pCi/L                    | pCi/L: picocuries per liter (a measure of radioactivity) |
| NA                       | NA: not applicable                                       |
| ND                       | ND: Not detected   |
| NR                       | NR: Monitoring not required, but recommended.            |

| <b>Important Drinking Water Definitions</b> |   |
|---|---|
| <b>Term</b>                                 | <b>Definition</b>   |
| MCLG  | MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.  |
| MCL   | MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.   |
| TT  | TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.  |
| AL  | AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.   |
| Variances and Exemptions                    | Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.   |
| MRDLG                                       | MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants. |
| MRDL  | MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.                              |
| MNR   | MNR: Monitored Not Regulated  |
| MPL   | MPL: State Assigned Maximum Permissible Level   |

**For more information please contact:**

Contact Name: Rolland Howell  
Address: Box 531  
Wrangell, AK 99929  
Phone: 907-874-3904