

**CITY AND BOROUGH OF WRANGELL, ALASKA**  
**WRANGELL COURTHOUSE CARPET REPLACEMENT**

**Addendum to the Contract**

---

**Addendum No: 1**

**Current Bid Opening Date:  
October 20, 2016 at 10:00 AM**

Pages This Addendum: One (1)

Previous Addenda: None (0)

---

**To: All Bidders of Record**

**October 17, 2016**

The contract documents are modified as indicated herein. All other terms and conditions remain unchanged. Bidders are required to acknowledge this addendum. Make the following additions to the contract documents:

**Item 1: SPECIFICATIONS**

Section 096813 Tile Carpeting: Replace Part 2.1, A with following carpet product:

A. Product: Mannington Everywear III, Modular

**Item 2: SPECIFICATIONS**

Section 096813 Tile Carpeting: Replace Part 2.2, C with following rubber product:

C. Rubber Wall Base and Accessories Products.

1. BurkeBase® Rubber Wall Base
2. Roppe 700 Series
  - a. Rubber Cove Wall Base:, Type TP, 1/8" Standard Toe, 4" height, 4' lengths. Utilize products from the same manufacturer for other flooring accessories and trim.
  - b. Rubber Base Adhesive: Manufacturer's recommended rubber products adhesive.
  - c. Rubber Floor Moldings. Apply overlap edge strips during flooring installation. Secure units to the substrate, complying with the edge strip manufacturer's recommendations. Provide transitions with profile and height to protect exposed edges of flooring products, and of maximum lengths to minimize running joints.
    - i. Carpet to Resilient Transition.
    - ii. Stair Nosing Transition.

END OF ADDENDUM NO. 1